TCD210236AC Autonics

# Thumbwheel Switch Temperature Controllers



## T3 / T4 Series PRODUCT MANUAL

For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

The specifications, dimensions, etc are subject to change without notice for product improvement Some models may be discontinued without notice.

#### **Features**

- Various control output options: relay, SSR drive, current
- 2 independent set points and control outputs for heating and cooling control (T4LP)
- Various sizes (W48 $\times$ H48, W48 $\times$ H96, W72 $\times$ H72, W96 $\times$ H96 mm)

#### **Safety Considerations**

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- ▲ symbol indicates caution due to special circumstances in which hazards may occur.

⚠ Warning Failure to follow instructions may result in serious injury or death

- 01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)
  Failure to follow this instruction may result in personal injury, economic loss or fire.
- 02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact or salinity may be present.

Failure to follow this instruction may result in explosion or fire.

- 03. Install on a device panel to use.
  - Failure to follow this instruction may result in electric shock.
- 04. Do not connect, repair, or inspect the unit while connected to a power source

Failure to follow this instruction may result in fire or electric shock.

- 05. Check 'Connections' before wiring.
  - Failure to follow this instruction may result in fire.
- 06. Do not disassemble or modify the unit.

Failure to follow this instruction may result in fire or electric shock.

⚠ Caution Failure to follow instructions may result in injury or product damage

01. When connecting the power input and relay output, use AWG 20 (0.50 mm²) cable or over, and tighten the terminal screw with a tightening torque of 1.0 N m.

When connecting the sensor input and communication cable without dedicated cable, use AWG 28 to 16 cable and tighten the terminal screw with a tightening torque of 1.0 N m.

Failure to follow this instruction may result in fire or malfunction due to contact failure.

- 02. Use the unit within the rated specifications.
  - Failure to follow this instruction may result in fire or product damage
- **03.** Use a dry cloth to clean the unit, and do not use water or organic solvent. Failure to follow this instruction may result in fire or electric shock.
- Keep the product away from metal chip, dust, and wire residue which flow into the unit.

 $\label{prop:control} \textit{Failure to follow this instruction may result in fire or product damage}.$ 

#### **Cautions during Use**

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents
- Check the polarity of the terminals before wiring the temperature sensor. For RTD temperature sensor, wire it as 3-wire type, using cables in same thickness and length.
   For thermocouple (TC) temperature sensor, use the designated compensation wire for extending wire.
- Keep away from high voltage lines or power lines to prevent inductive noise. In case
  installing power line and input signal line closely, use line filter or varistor at power line
  and shielded wire at input signal line. Do not use near the equipment which generates
  strong magnetic force or high frequency noise.

- Install a power switch or circuit breaker in the easily accessible place for supplying or disconnecting the power.
- Do not use the unit for other purpose (e.g. voltmeter, ammeter), but temperature controller.
- Make a required space around the unit for radiation of heat. For accurate temperature measurement, warm up the unit over 20 min after turning on the power.
- Install a surge absorber at each end of inductive load coil when controlling high-capacity power relay or inductive load (e.g. magnet).
- $\bullet \ \mathsf{Make} \ \mathsf{sure} \ \mathsf{that} \ \mathsf{power} \ \mathsf{supply} \ \mathsf{voltage} \ \mathsf{reaches} \ \mathsf{to} \ \mathsf{the} \ \mathsf{rated} \ \mathsf{voltage} \ \mathsf{within} \ \mathsf{2} \ \mathsf{sec} \ \mathsf{after} \\$ supplying power.
- Do not wire to terminals which are not used.
- This unit may be used in the following environments.
- Indoors (in the environment condition rated in 'Specifications')
- Altitude Max. 2,000 m
- Pollution degree 2
- Installation category II

#### **Ordering Information**

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website .

T 0 2 8 - 4 5 6 7 8 - 9	
-------------------------	--

#### Digit

3:3 digit

4:4 digit

#### Size

S: DIN W 48  $\times$  H 48 mm (8 pin plug type) M: DIN W 72  $\times$  H 72 mm H: DIN W  $48 \times H$  96 mm

L: DIN W 96  $\times$  H 96 mm

#### **3** Option output

#### Control method

B: ON/OFF / Proportional

PN	Option output	T3S	тзн	T4M	T4L
No mark	No output	0	0	0	0
Α	Alarm	-	0	0	0
S	Option	-	0	-	-
Р	Dual setting	-	-	-	0

#### O Power supply

4: 100-240 VAC 50/60Hz

#### **6** Control output

R: Relay S: SSR drive

C: Current

#### 1 Input type and using range

PN	Input type		Using range	T3S	тзн	ТЗНА	тзнѕ	T4M T4MA	T4L T4LA	T4LP						
K4			0 to 400 °C	0	0	0	0	0	0	0						
K8 KA	(I)	K(CA)	0 to 800 °C	0	0	0	-	0	0	0						
KA	aldn	N(CA)	0 to 999 °C	-	0	0	-	-	-	-						
KC	mocol		0 to 1200 °C	-	-	-	-	0	0	0						
J2	돌 기(IC)	J.	JW.	Ĭ.	ĬĔ	ĬĔ	JW.	Ĕ E	0 to 200 °C	0	-	-	-	-	-	-
J4		J(IC)	0 to 400 °C	0	0	0	0	0	0	0						
J8			0 to 800 °F	-	0	-	-	-	-	-						
RF		R(PR)	600 to 1600 °C	-	-	-	-	0	0	0						
P0			-99.9 to 199.9 ℃	-	-	-	-	0	0	-						
P0			-99 to 199 ℃	-	0	0	-	-	-	-						
P1	٥	DPt	0 to 99.9 °C	0	0	-	-	-	-	-						
P2	2	100Ω	0 to 200.0 °C	-	-	-	-	-	-	0						
P2			0 to 200 °C	0	-	-	-	-	-	-						
P4			0 to 400 °C	0	0	0	0	0	0	0						

O Version

N: New

#### **3** Temperature unit

C: Celsius (°C)

F: Fahrenheit (°F)

• Contact us for temperature unit °F model.

Power su	pply	100 - 240 VAC∼ 50/60 Hz				
Permissil range	ole voltage	90 to 110 % of rated voltage				
Power co	nsumption	≤5 VA				
Sampling	gperiod	100 ms				
Input spe	cification	Refer to 'Ordering Information: Input type and using range'.				
Display a	ccuracy <sup>01)</sup>	• At room temperature (23 °C $\pm$ 5 °C): (PV $\pm$ 0.5% or $\pm$ 1 °C higher one) $\pm$ 1 digit • Out of room temperature range: (PV $\pm$ 0.5% or $\pm$ 2 °C higher one) $\pm$ 1 digit				
Control	Relay <sup>02)</sup>	OUT1: 250 VAC~ 5 A / 30 VDC== 5A 1c, OUT2: 250 VAC~ 2 A / 30 VDC== 2A 1c				
output	SSR	12 VDC=±2 V, ≤ 20 mA				
	Current	DC 4-20 mA, Load resistance: $\leq 500 \Omega$				
Option or	utput	250 VAC~ 2 A 1c				
Alarm ou range	tput setting	F.S. 0 to 10% (volume switch)				
Option output setting range		0 to 50 °C (volume switch)				
Reset range		F.S3 to 3% (volume switch)				
Display type		7 segment (red), LED type				
Control t	ype	ON/OFF, Proportional control				
Hysteresi	is	F.S. 0.2 to 3% (T3S: F.S. 0.5%) (volume switch)				
Proportio	onal band	F.S. 1 to 10% (T3S: F.S. 3%) (volume switch)				
Proportio	onal cycle	20 sec				
Relay	Mechanical	≥ 5,000,000 operations				
life cycle	Electrical	OUT1: $\geq$ 100,000 operations, OUT2: $\geq$ 200,000 operations				
Dielectric	strength	Between the charging part and the case: 2,000 VAC $\sim 50/60~{\rm Hz}$ for $1~{\rm min}$				
Vibration		0.75 mm amplitude at frequency of 10 to 55 Hz in each X, Y, Z direction for 2 hours				
Insulation resistance		$\geq$ 100 M $\Omega$ (500 VDC== megger)				
Noise immunity  Memory retention		$\pm 2\text{kV}$ square shaped noise by noise simulator (pulse width 1 $\mu\text{s})$ R-phase, S-phase				
		≈ 10 years (non-volatile semiconductor memory type)				
Ambient	temperature	-10 to 50 °C, storage: -20 to 60 °C (no freezing or condensation)				
Ambient	humidity	35 to 85%RH, storage: 35 to 85%RH (no freezing or condensation)				
Certificat	tion <sup>03)</sup>	ERC				
Unit weig	ght (packaged)	• T3S: ≈ 95 g (≈ 135 g) • T3H, T3HA, T3HS: ≈ 176 g (≈ 239 g) • T4M, T4MA: ≈ 180 g • T4I, T4I A, T4I P: ≈ 222 g (≈ 310 g)				

01) In case of the T3S Series and the decimal point display models At room temperature (23 °C  $\pm$ 5 °C): (PV  $\pm$ 0.5% or  $\pm$ 2 °C higher one)  $\pm$ 1 digit Out of room temperature range: (PV  $\pm$ 0.5% or  $\pm$ 3 °C higher one)  $\pm$ 1 digit

02) Dual setting output of the T4LP is fixed as relay output and, it is also available as alarm output.

03) Certification attainment may vary depending on the model. Check the certification on the Autonics website.

#### **Product Components**

• Product (+ bracket)

· Instruction manual


#### **Sold Separately**


- 8-pin controller socket: PG-8, PS-8 (N)
- Terminal protection cover: RMA / RHA / RLA-COVER

ecifi	

Series		T3, T4 Series				
Power su	pply	100 - 240 VAC∼ 50/60 Hz				
Permissible voltage range		90 to 110 % of rated voltage				
Power co	nsumption	≤5 VA				
Sampling	period	100 ms				
Input spe	cification	Refer to 'Ordering Information: Input type and using range'.				
Display a	ccuracy <sup>01)</sup>	• At room temperature (23 °C $\pm$ 5 °C): (PV $\pm$ 0.5% or $\pm$ 1 °C higher one) $\pm$ 1 digit • Out of room temperature range: (PV $\pm$ 0.5% or $\pm$ 2 °C higher one) $\pm$ 1 digit				
Control	Relay <sup>02)</sup>	OUT1: 250 VAC~ 5 A / 30 VDC== 5A 1c, OUT2: 250 VAC~ 2 A / 30 VDC== 2A 1c				
output	SSR	$12 \text{ VDC} = \pm 2 \text{ V}, \leq 20 \text{ mA}$				
	Current	DC 4-20 mA, Load resistance: $\leq$ 500 $\Omega$				
Option or	ıtput	250 VAC~ 2 A 1c				
Alarm ou range	tput setting	F.S. 0 to 10% (volume switch)				
Option or range	utput setting	0 to 50 °C (volume switch)				
Reset ran	ge	F.S3 to 3% (volume switch)				
Display ty	/pe	7 segment (red), LED type				
Control t	ype	ON/OFF, Proportional control				
Hysteresi	S	F.S. 0.2 to 3% (T3S: F.S. 0.5%) (volume switch)				
Proportio	onal band	F.S. 1 to 10% (T3S: F.S. 3%) (volume switch)				
Proportio	onal cycle	20 sec				
Relay	Mechanical	≥ 5,000,000 operations				
life cycle	Electrical	OUT1: $\geq$ 100,000 operations, OUT2: $\geq$ 200,000 operations				
Dielectric	strength	Between the charging part and the case: 2,000 VAC $\sim 50/60~{\rm Hz}{\rm for}$ 1 min				
Vibration		0.75 mm amplitude at frequency of 10 to 55 Hz in each X, Y, Z direction for 2 hours				
Insulation	n resistance	$\geq$ 100 M $\Omega$ (500 VDC== megger)				
Noise im	nunity	±2 kV square shaped noise by noise simulator (pulse width 1 μs) R-phase, S-phase				
Memory retention		≈ 10 years (non-volatile semiconductor memory type)				
Ambient	temperature	-10 to 50 °C, storage: -20 to 60 °C (no freezing or condensation)				
Ambient humidity		35 to 85%RH, storage: 35 to 85%RH (no freezing or condensation)				
Certificat	ion <sup>03)</sup>	ERC				
Unit weig	tht (packaged)	$ \begin{split} \bullet \text{T3S:} \approx 95 \text{ g} &(\approx 135 \text{ g}) & \bullet \text{T3H, T3HA, T3HS:} \approx 176 \text{ g} &(\approx 239 \text{ g}) \\ \bullet \text{T4M, T4MA:} &\approx 180 \text{ g} \\ &(\approx 246 \text{ g}) & \bullet \text{T4L, T4LA, T4LP:} \approx 222 \text{ g} &(\approx 310 \text{ g}) \end{split} $				

#### **Unit Descriptions**





#### 1. PV (Present value) display part (Red)

#### 2. Control output (OUT) Indicator

Turns ON when control output is ON.

 $\bullet$  In case of the T3S, the upper DOT of last digit flashes.

#### 3. Alarm/Option output (AL / SUB) Indicator

Turns ON when alarm/option output is ON. (only for alarm output model)

#### 4. SV (Setting value) thumbwheel switch [-]: Decreases number, [+]: Increases number

- The models which temperature range is 0 (-99.9 to 199.9°C, -99 to 199°C) of temperature sensor DPt100 $\Omega$  are only set  $1 \mathop{\leftrightarrow}^{\cdot} 0 \mathop{\leftrightarrow}^{\cdot} (\text{-}).$
- The dual setting output model (T4LP) has two thumbwheel switches.


LO SET	HI SET				
1 2 3 4					
Low set output: Heating control	High set output: Cooling control				

#### 5. Volume switch


Display	Name	Description
P.B %	Hysteresis / Proportional band	ON/OFF control: Setting for hysteresis Proportional control: Setting for proportional band • Except T3S
AL%	Alarm output	Setting for alarm output
RESET	Reset	In case of proportional control, it sets offset.
SUB Option output SV		Setting for deviation low limit alarm temperature
	·	

#### **Connections**


#### **■** T3S




#### ■ T4M/T4MA



#### ■ T3H/T3HA/T3HS



#### **■ T4L/T4LA/T4LP**



#### **Crimp Terminal Specifications**

• Unit: mm, Use the crimp terminal of follow shape.






Fork crimp terminal

Round crimp terminal

#### **Dimensions**

- $\bullet$  Unit: mm, For the detailed drawings, follow the Autonics website.
- Below is based on T3S Series.









	Body						Panel cut-out			
	Α	В	С	D	E	F	G	н	I	J
T3S	48	48	10.5	12.3	77.8	□45	≥ 65	≥ 65	45 <sup>+0.6</sup>	45 <sup>+0.6</sup>
ТЗН	48	96	13	-	70	91.5	≥ 65	≥ 115	45 <sup>+0.6</sup>	92 0 0
T4M	72	72	11.8	14.3	75	□67.5	≥ 90	≥ 90	68 0	68 0
T4L	96	96	12.5	-	70	□91.5	≥ 115	≥ 115	92 0 0	92 0 0

#### ■ Bracket






#### **Control Type Setting**

Before supplying power, detach the case and set the control method by the control type setting switch.

#### ■ Detaching the case


T3S





Press the peaks (1) on both side with your thumb. Pull the case to the 2 direction and it is removed.

#### ■ Control type setting switch



P: Proportional control (default) F: ON/OFF control

### Initial Display When Power is ON

When power is supplied, whole display parts turn ON for 1 sec. After displaying model  $\,$ type, it returns to RUN mode.

• During displaying model type, control output does not operate.

1. All display	2. Digit, alarm/ option output				
8.8.8.8	£35	-P4[	200		

#### **Errors**


			Output				
D	isplay	Description	Control <sup>01)</sup>	Alarm	Option	Dual setting	Troubleshooting
	oPEn	Flashes when input sensor is disconnected or sensor is not connected.	OFF	ON	OFF	ON	Check input sensor status.
	нннн	Flashes when PV is higher than using range. <sup>02)</sup>	OFF	ON	OFF	ON	When input is within the rated
	LLLL	Flashes when PV is lower than using range. (22)	ON	ON	ON	OFF	using range, this display disappears.
	Su.Er	SV.ER and PV are cross flashed when SV is out of using range • When error and the others occur at the same time, they are crossed flashed.	OFF	OFF	OFF	OFF	Set SV in using range.

<sup>01)</sup> In case of T4LP (Dual setting output), it is adapted to the single output.

<sup>02)</sup> Be careful that when HHHH / L L L L error occurs, the control output may occur by recognizing the maximum or minimum input depending on the control type.


#### [T3HS Series] Function: Option Output

This output operates as deviation low-limit alarm. (Hysteresis: 2°C, fixed)



#### [T4LP Series] Function: Dual Setting Output

- $\bullet$  LO SET (low set output): ON/OFF control, proportional control
- HI SET (high set output): Absolute value high-limit alarm output (Hysteresis: 2°C fixed)




#### Sold Separately: 8-pin Controller Socket


• For detailed information, refer to the 'PG Series, PS Series' manual.

Appearance	rance Pins R		Rated current	Feature	Model
	8-pin	250 VAC~	7 A (resistance load)	Controller socket	PG-08
	8-pin	250 VAC~	7 A (resistance load)	Controller socket (DIN Rail / Panel)	PS-08(N)


#### Sold Separately: Terminal Protection Cover

• Unit: mm





#### RLA-COVER: DIN W96 $\times$ H96



#### Segment Table

The segments displayed on the product indicate the following meanings. It may differ depending on the product.

7 Segment				11 Segment				12 Segment				16 Segment			
0	0	1	1	0	0	1		0	0	1	1	0	0	Ι	П
-1	1	J	J	-1	1	J	J	-1	1	J	J	-1	1	ŭ	J
2	2	F	K	2	2	K	K	2	2	К	K	2	2	ĸ	K
3	3	L	L	3	3	L	L	3	3	L	L	3	3	L	L
Ч	4	ñ	М	Ч	4	M	М	Ч	4	M	М	Ч	4	M	М
5	5	n	N	5	5	N	N	5	5	N	N	5	5	N	N
6	6	0	0	6	6	0	0	Б	6	٥	0	Б	6	Ð	0
7	7	Р	Р	7	7	Ρ	Р	7	7	Ρ	Р	7	7	Ρ	Р
8	8	9	Q	8	8	0	Q	8	8	ū	Q	8	8	Q	Q
9	9	۲	R	9	9	R	R	9	9	R	R	9	9	R	R
R	Α	5	S	Я	Α	5	S	А	Α	5	S	Я	Α	5	S
ь	В	Ł	Т	Ь	В	Ł	Т	Ь	В	Ł	Т	3	В	T	Т
Ε	С	П	U	Ε	С	Ш	U	Ε	С	Ш	U	Е	С	Ш	U
Ь	D	u	V	d	D	V	٧	d	D	V	V	D	D	V	V
Ε	Е	ū	W	Ε	Ε	М	W	Ε	Ε	М	W	Ε	Ε	И	W
F	F	4	Х	F	F	X	Χ	F	F	X	Х	F	F	×	Х
G	G	У	Υ	ū	G	У	Υ	5	G	У	Υ	5	G	Y	Υ
Н	Н	Ξ	Z	Н	Н	Z	Z	Н	Н	Z	Z	Н	Н	Z	Z